



FIRE SAFETY CERTIFICATE

No. 1614/30/2024

Dated: 20.09.2024

Certified that the Dr. Suryadeo Heritage school, at Chandan Nagar, P.O. - Nawagarhi, Thana - Mufasil, Dist - Munger, Bihar - 811211 comprised of Ground Floor and First Floor owned by Dr. Suryadeo Thakur Memorial Trust, Chandan Nagar, Nawagarhi, Mufasil, Munger, Bihar - 811211 have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules and verified by the officers concerned of Fire Service Department, Munger Division on June 30, 2024 in the presence of Mr. Rishi Ranjan Kumar, Manager, Dr. Suryadeo Heritage School, Chandan Nagar, P.O. - Nawagarhi, Thana - Mufasil, Dist - Munger, Bihar - 811211 that the building/premises is fit for occupancy of classes upto Std VIII and above with effect from 19.04.2024 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended.

- 1.)
 - 2.)
 - 3.)
 - 4.)
- 

 20.9.24

Issued on 20/09/2024 at Munger by Fire Safety Officer, Munger by

Signature with Seal:  20.09.24
 अधिष्ठाता अग्निशामालय पदाधिकारी
 Name : Ravindra Kumar Singh, मुंगेर, बिहार
 Designation : Fire Station Officer, Munger

 20.9.24

To,
 The President/Principal,
 Dr. Suryadeo Heritage School
 Chandan Nagar, P.O. - Nawagarhi
 Thana - Mufasil, Dist - Munger, Bihar - 811211


Principal

Dr. Suryadeo Heritage School
 Chandan Nagar, Nawagarhi, Munger

ENDORSEMENT


Manager
 Dr. Suryadeo Heritage School
 Chandan Nagar, Nawagarhi, Munger

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

 (Reasons to be recorded).

(Name and designation of the authorized signatory)

कार्यालय, निदेशक-सह-राज्य अग्निशमन पदाधिकारी, बिहार, पटना।

पत्रांक 378-127 D 44/ (I-2022) Part IV

दिनांक 13.08.2024.



0612-2222020

sfo cum director-bih@gov.in

सेवा में,

डा० सुर्यदेव हेरिटेज स्कूल,
चन्दन नगर नैवागढ़ी दरियापुर जगालपुर, मुंगेर।
(Email id: dr.schschooll@gmail.com)

विषय:- अग्नि अंकेक्षण प्रमाण-पत्र के संबंध में।

महाशय,

उपर्युक्त विषय के संबंध में प्रमाणित किया जाता है कि डा० सुर्यदेव हेरिटेज स्कूल, चन्दन नगर नैवागढ़ी दरियापुर जगालपुर, मुंगेर में अवस्थित है। अनुमण्डल अग्निशामालय पदाधिकारी, तारापुर द्वारा दिनांक 19.04.2024 को अग्नि अंकेक्षण किया गया है। पुनः दिनांक 30.06.2024 को जाँच कर अनुपालन प्रतिवेदन समर्पित है। राष्ट्रीय भवन संहिता 2016 एवं बिहार अग्निशमन सेवा नियमावली 2021 के तहत लगाये गये अग्निशमन यंत्र एवं अन्य अग्नि सुरक्षा उपकरण पर्याप्त प्रतीत होते हैं।

अतः उक्त संस्थान का वार्षिक अग्नि अंकेक्षण प्रमाण-पत्र की वैधता दिनांक 18.04.2025 को समाप्त हो जायेगी। संस्थान प्रबंधक/मालिक पुनः दिनांक 19.04.2025 को अग्नि अंकेक्षण कराना सुनिश्चित करें।

ह०/-

निदेशक-सह-राज्य अग्निशमन पदाधिकारी,
बिहार, पटना।

- प्रतिलिपि:- 01. जिला समादेष्टा-सह-जिला अग्निशमन पदाधिकारी, मुंगेर को सूचनार्थ एवं आवश्यक क्रियार्थ प्रेषित।
02. अनुमंडल अग्निशामालय पदाधिकारी, मुंगेर, को सूचनार्थ एवं आवश्यक क्रियार्थ प्रेषित।

13/08/24

निदेशक-सह-राज्य अग्निशमन पदाधिकारी,
बिहार, पटना।

Suryadev

Lishu Kuntan Kumar

Principal

Dr. Suryadeo Heritage School
Chandan Nagar, Nawagarhi, Munger

Manager

Dr. Suryadeo Heritage School
Chandan Nagar, Nawagarhi, Munger