

ग्राम पंचायत राज नौवागढी उत्तरी

प्रखण्ड : सदर मुंगेर, जिला : मुंगेर : 811211 (बिहार)

नविता कुमारी

मुखिया

आवास :

नया टोला भगतचौकी, नौवागढी (मुंगेर)

☎ : 8210714889

पत्रांक - 02 नौवागढी

दिनांक : 08.09.2024

TO WHOMSOEVER IT MAY CONCERN

This is to certify that the premises of Dr. Suryadeo Heritage School, At Chandan Nagar, Po-Nawagarhi, Ps-Mufasil Dist-Munger Pin Code-811211, Posses proper and hygienic sanitation facilities and clean and clear (RO) drinking water facilities on all floors (G+1) The school is properly and well maintained. We wish the school a bright future and success in all future endeavours.

Navita Kumari

मुखिया
ग्राम पंचायत राज, नौवागढी उत्तरी
सदर प्रखण्ड, मुंगेर

Government of Bihar
District Level Water Testing Laboratory
Public Health Engineering Department Munger

Sample collected And given by itself
District Munger
Date of sampling 15/05/2024

Date of Testing 16.05.2024

Particulars			Test Result (in mg/l)													Remarks (Safe/un safe)			
Sl. No.	Block Name	Panchayat Name	Village	Name of SCHOOL	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Fe	Alk	NO ₃		SO ₄	F	As (in ppb)
1	MUNGER SADAR	NAWAGARHI	CHANDAN NAGAR	DR.SURYADEO HERITAGE SCHOOL	7.58	1.53	984	640	440	120	34	110	0.2	400	0	0	0.56	BDL	
Desirable Limit					6.5-8.5	5	—	500	200	75	30	250	1.00	200	45	200	1.00	0.010	
Maximum Permissible Limit					NR	10	—	2000	600	200	150	1000	NR	600	NR	400	1.50	NR	

Ramesh Kumar
10/5/24
Chemist
PH Division, Munger



ON